

# EC Type Examination Certificate

Issued by BG Technology, Certification Services  
Gas Research & Technology Centre, Ashby Road, Loughborough, Leicestershire LE11 3GR

<i>NOTIFIED BODY NUMBER</i>	0087	<i>JOB NO.</i>	E30705
<i>CERTIFICATE NO.</i>	BG/EC-87/99/30/M1		
<i>DATE</i>	20 September 1999		
<i>ORIGINAL/SUPPLEMENTARY</i>	Supplementary		
<i>MANUFACTURER</i>	KARL DUNGS A/S VEJLEVEJ 21 DK-8722 HEDENSTED DENMARK		
<i>AGENT</i>	KARL DUNGS INC 524 APOLLO DRIVE SUITE 19 LINO LAKES MINNESOTA 55014 USA		
<i>PRODUCT TYPE</i>	Electrically Operated Shut-off Valves, Regulators and Accessories		
<i>MODEL DESIGNATION</i>	DMV-(D, DLE) 701/6, 702/6, 703/6 and FRI 705/6, 707/6, 710/6 & 712/6		
<i>GAS FAMILIES</i>	1st, 2nd and 3rd		
<i>DESTINATION COUNTRIES</i>	All EU Countries		
<i>SUPPLY PRESSURES</i>	500mbar maximum		
<i>EC PRODUCT IDENT. NO.</i>	87AU30		

Note : This supplementary certificate has been issued to include a new model designation for the Fri 700 Regulators.

## DECLARATION

Type samples representative of the above mentioned product have been tested and examined and found to comply with the Essential Requirements detailed in Annex I of the European Gas Appliance Directive (90/396/EEC) by compliance with EN 161:1991 and EN 88: 1991.

Signed on behalf of Notified Body

**BG Technology** 

BG Technology is a part of BG plc which includes Transco (in the UK) and British Gas International  
BG plc Registered in England No. 2006000 Registered Office 100 Thames Valley Park Drive, Reading, Berkshire RG6 1PT

  
G D McKay  
Manager  
BG Technology  
Certification Services