



# AGA CERTIFIED PRODUCT

Certificate Holder: **KARL DUNGS GMBH & CO. KG**

ABN/ACN No. (if applicable): **N/A**

Manufacturer: **Karl Dungs GmbH & Co. KG**

Agent (if applicable): **Techrite Controls Australia Pty Ltd**

Type of Component: **Automatic Safety Shut-Off Valve  
Class 1**

Model No. & Description: **Dungs  
MV, MVD, MVDLE Series**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)*  
See Page 2

Relevant Standard(s): **AS 4629 – 2005  
(Incorporating Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **17 January 1990**

Certificate No: **4522**

This copy valid from: **4 July 2016**

Refer specification issue: **07**



# AGA CERTIFIED PRODUCT

Model No. & Description:

**Dungs  
MV, MVD, MVDLE Series**

20 kPa	36 kPa	50 kPa
<b>MV</b>		
<b>205/4</b> (DN 15), <b>207/4</b> (DN 20), <b>210/4</b> (DN 25), <b>215/4</b> (DN 40), <b>220/4</b> (DN 50), <b>2125/5/S</b> (DN 125), <b>2150/5 S</b> (DN 150)		<b>502</b> (DN 8), <b>5100/5 S</b> (DN 100)
<b>MVD</b>		
<b>207/5</b> (DN 20), <b>215/5</b> (DN 40), <b>220/5</b> (DN 50), <b>225/5</b> (DN 65), <b>2020/5</b> (DN 20), <b>2040/5</b> (DN 40), <b>2050/5</b> (DN 50), <b>2065/5</b> (DN 65), <b>2080/5</b> (DN 80), <b>2100/5</b> (DN 100)	<b>203/5</b> (DN 10), <b>205/5</b> (DN 15), <b>207/5</b> (DN 20), <b>210/5</b> (DN 25), <b>215/5</b> (DN 40), <b>2020/5</b> (DN 20), <b>2025/5</b> (DN 25), <b>2040/5</b> (DN 40)	<b>503/5</b> (DN 10), <b>505/5</b> (DN 15), <b>507/5</b> (DN 20), <b>510/5</b> (DN 25), <b>515/5</b> (DN 40), <b>520/5</b> (DN 50), <b>525/5</b> (DN 65), <b>5020/5</b> (DN 20), <b>5025/5</b> (DN 25); <b>5040/5</b> (DN 40), <b>5050/5</b> (DN 50), <b>5065/5</b> (DN 65), <b>5080/5</b> (DN 80), <b>5100/5</b> (DN 100), <b>5125/5</b> (DN 125), <b>5150/5</b> (DN 150)
<b>MVDLE</b>		
<b>215/5</b> (DN 40), <b>220/5</b> (DN 50), <b>225/5</b> (DN 65), <b>2040/5</b> (DN 40), <b>2050/5</b> (DN 50), <b>2065/5</b> (DN 65), <b>2080/5</b> (DN 80), <b>2100/5</b> (DN 100)	<b>203/5</b> (DN 10), <b>205/5</b> (DN 15), <b>207/5</b> (DN 20), <b>210/5</b> (DN 25), <b>215/5</b> (DN 40), <b>2020/5</b> (DN 20), <b>2025/5</b> (DN 25), <b>2040/5</b> (DN 40)	<b>503/5</b> (DN 10), <b>505/5</b> (DN 15), <b>507/5</b> (DN 20), <b>510/5</b> (DN 25), <b>515/5</b> (DN 40), <b>520/5</b> (DN 50), <b>5020/5</b> (DN 20), <b>5025/5</b> (DN 25), <b>5040/5</b> (DN 40), <b>5050/5</b> (DN 50)

Client Manager

Certificate Authorised

Certificate first issued: **17 January 1990**

Certificate No: **4522**

This copy valid from: **4 July 2016**

Refer specification issue: **07**